th-Tune new firmware 1.1 Programmers' guide

Ver. 5.0

26/11/2014



Integrated Control Solutions & Energy Savings

Introduction

This presentation provides some basic explanation to develop an application with one th-Tune display connected to a programmable controller.

The features here described refer to the new firmware version (1.1); the firmware version is displayed at the power on of the display.

As a consequence there are some differences between this programmers guide and the former one (referred to the 1.0 firmware version. There will be also a new version of 1tool but it's not strictly necessary to have it (the new version will improve usability). The references to th-Tune characteristics that changed are displayed with this icon

The th-Tune can be used with two different types of protocol in the programmable controller; these two connections have different possibilities (indicated with different colors) so the described features will have a correspondent color indication to show if it's available for both options or not



Topics 1/3

Main features Product overview, applications

Applications

- Display structure and Terminal usage overview display area, how to modify status, key function (pre-defined), ...
 - How to create new project for th-Tune Solution Exp.editing limits, Windows, Properties, Languages, N.of mask
- 5

Terminal Editor components and Editing Display area, Key area, Tab area, Hot area: Mode, Fan, Icons, Scheduler, Big/SmallArea. How to assign a variable to a 'function'. Automatic creation of variables, Copy/Move of variable

Configuration of communication parameters



Topics 2/3







Tab Alarms



Tab Scheduler and Terminal (to be removed)



Terminal parameters



Main features 1/3



- Standard power supply (115..230 Vac) or 24 Vac/Vdc
- Temperature and Humidity measurements
- Internal clock
- Compatible with IT, DE, CN and US flush mounting sockets
- Time schedule: 5+2 or 7 days programs and single day programs (up to 6 time bands per day)
- Communication with the controller:
 - RS485 with "Modbus master protocol" blue colour is indicating the protocol in this presentation
 - More terminal/device on the same net
 - Only <u>basic function</u> are available
 - Traditional programming of a modbus device
 - RS485 with "th-Tune protocol" orange colour is

indicating the protocol in this presentation

- Only one th-Tune terminal can be connected
- It'd not possible to connect other devices
- Available only FieldBus port
- It's "Modbus master protocol" managed by BIOS
- Specific terminal editor in 1tool
- Operating conditions: -10T50°C



Main features 2/3

- Easy To use
- User Terminal as well as Commissioning terminal
- Compatible with the most common wall sockets available in the market







Main features 3/3



- "Dummy" user interface (predefined keyfunction & navigation must be supported by the controller)
- Can be used together with PGD* terminals
- "thTune protocol" FieldBus serial port or "serial 0"
- Programmable by 1tool
- Support module available soon
- Supported by: pCO1* (=>2MB flash), pCO3, Supernode, pCO5)
- 1tool version: => 2.0.31 or higher
- BIOS: => 5.11, 04/10/2010
- Firmware: => 1.1



th-Tune **Application:** unit display Advanced functions

Bringing it on the unit it's possible to see all the parameters with a single display: up to 15 categories of parameters

2



th-Tune **Application:** user terminal for basic settings

ON-OFF, setpoints, temperature and humidity measurement, function enabling, TIME BANDS messages and icons



Using standard modbus only basic functions are available but it's possible to insert more displays and different devices (the limit is speed of information) Room







Display structure and Terminal usage overview 1/3





3



Display structure and Terminal usage overview 2/3

"Mode"

When pressing the '**Mode**' button, the symbol relating to one of the 5 modes available will be shown:

- Heating
- Cooling
- Automatic
- Dehumidification
- Water

(these are the most common associated functions to those symbols but the real operation depends on application)

"Clock"

When pressing the button marked by the '**Clock**' symbol, the terminal will switch to time band setting mode. Keeping the button pressed it will be possible to enter in Clock and Time bands settings



"Fan"

When pressing the button marked by the '**Fan**' symbol, the speed bar will show the next level.

"Power On/Off"

When pressing the button marked by the '**Power On/Off**' symbol, the terminal will show 'OFF' in the centre of the display.

In special menus (time bands and clock settings, alarm menu, parameters menu is equivalent to ESC function)





Display structure and Terminal usage overview 3/3



2



How to create new prj for th-Tune (if using th-Tune protocol)



- Only 1 mask/terminal
- Most part of editing menu/tools/properties are disabled.
 Example: Toolbox/NormalMask only, Configure Languages, Delete, unused
 SpecialFields, KeyFunctionEditor, ResourceUsedOnBool, etc.
- NOTE: When compiling a *.iup is generated to be downloaded in the controller ONLY if there is no other *.iup

How to create new prj for th-Tune (if using Modbus master protocol)

- Check list of variables available in Modbus
- Use de Modbus master DEMO to understand how it works
- Develop your own application integrating the th-Tune as a simple Modbus device
- Please note that some integer bit field variables in the th-Tune editor must be sent as separate coils in modbus protocol (in th-Tune protocol the bios is automatically doing that)
- Make sure that you set the right variables for configuration (see section 7)



Terminal Editor components and Editing 1/2

'Button area' of the terminal.

`Functions tab'

This shows the graphic symbols for the 5 functions ('Mode', 'Fan', 'Clock', 'Power' & 'Alarms') on the display that can be associated with a variable dragging it from the 'Variable List'.

'Parameters tab'

This lists the parameters designated to be manually set by the user, dragging them directly from the 'Variable List'.



'Icons tab'

This lists all the graphic symbols relating to the functions on the display that can be associated with a **variable** by dragging it from the *`Variable List'*.



`Alarms tab'

This lists the variables relating to the alarms used in the application.

Terminal Editor components and Editing 2/2

N*

001

002

003

- How to associate a Variable to a Symbol/Function/Status/Variable
 - drag&drop from *Variablelist* to Symbol/Function/Status/Variable or to Listview
 - Type the variable in the **Listview**
- Shortcut
 - MOVE and CTRL+MOVE (=copy) available
 - CTRL+X/C/V not available
- Automatic creation of support variables: Right-click the mask, *Replace variables...*
- *th-Tune* support module and demo (preliminary version is available) is recommended as a possible starting point for new projects



0

0

R

2

Undo

Redo

Delete

Properties

Configuration of communication system variables

- Inside project you must set this comunication parameters on FieldBus port
 - COM_PROTOCOL_FIELDBUS=19 (th-Tune protocol)
 - COM_BAUDRATE_FIELDBUS=4 (19200baud)



NOTE

6

- *th-Tune protocol'* is available on FieldBus port but also on serial 0 (pLAN for small lenghts of the cables). For serial line 0 you'll have to set the specific system variable
- *th-Tune protocol*' support only **one** th-Tune terminal
- Comunication between pCO and terminal is managed automatically by BIOS
- 1tool provides to user a quickly and simple graphical interface to manage th-Tune variables read/written by BIOS





Make sure that baudrate and address on the th-Tune are correct: see section 18 for th-Tune parameters.



Terminal configuration configuration and status variables

There are some variables indicating the status and the configuration of the terminal that must be used for basic settings of th-Tune behaviour. Make sure that you set these variables in the right way to configure the main features of the terminal and then design the functions with the following section 7





Terminal configuration Cfg_flags

Use Cfg_flags variable to configure the terminal

BIT	Function	Description
0	Bypass "INIT funtion"	This flag tells to terminal to bypass the initialization phase used for parameters and alarms in "th -Tune protocol" MUST be used when communicating in MODBUS otherwise it's not necessary
3	measure unit of temperature displayed	This flag tells to terminal which unit of measure is used to represent the temperature (°C or °F), so as to show the corresponding symbol (displays symbol in Big/SmallArea with conversion). $0 = ^{\circ}C$ $1 = ^{\circ}F$
4	measure unit of pressure displayed	This flag tells to terminal which unit of measure is used to represent the pressure (BAR or PSI), so as to show the corresponding symbol (displays only symbol in SmallArea, <u>without conversion</u>). 0 = BAR 1 = PSI
5	Load time events	This flag tells to terminal to copy in the scheduler the BMS variables for time bands, that are available in R/W mode only in Modbus protocol
9	Hours display	0 to display hours of the internal clock, 1 to display hours sent by pCO (see "Internal clock")
10	Time band 1	If 1, the time band 1 isn't used and displayed
11	Time band 2	If 1, the time band 1 isn't used and displayed
12	Time band 3	If 1, the time band 1 isn't used and displayed
13	Time band 4	If 1, the time band 1 isn't used and displayed
14	Time band 5	If 1, the time band 1 isn't used and displayed
15	Time band 6	If 1, the time band 1 isn't used and displayed
other	Reserved	Not used

NOTE:

when using Modbus protocol, it's necessary to write directly the coils for each specific enabling



Terminal configuration Status_Flag

• Status_flags variable

- status register of the terminal used to provide general information.

BIT	Function	Description
0	Heartbeat	Managed by pCO BIOS. Terminal sets to 1 this bit after a power off, or when the th-Tune doesn't detect any valid interrogation from a Modbus supervisor to a Modbus slave in the same network within 30 seconds (terminal displays " c_{π} "). When BIOS sees to 1 this bit, it sends all variables to terminal and sets this bit to 0 (so all variables are aligned).
1	"Time bands" enabling	The state of this flag is changed by terminal with a short-press of "CLOCK" key, user in this way can enable/disable "Time Bands". The display shows this icon when "Time Bands" are enable. (see section 12)
4	Custom function	If =1 the "custom function" is active (see section 11)
5	Internal clock (RTC)	=1 (internal clock always present)
7	External-Internal Scheduler	This flag is set to 1/0 by <u>application</u> to configure 0= "Time bands" are managed by the pCO that must have the scheduler in its memory, change the setpoint, the current time band and the "Power" variable 1= "Time bands" are managed by the th-Tune that changes the setpoint. Automatically with this option the set editing function is disabled writing the specific bit of "key_enable_mask" variable, but it's always possible to enable it from application
15	Terminal online/offline	Application can only read bit15: 0=terminal online, 1=terminal offline. This bit is set to 1 by bios when using th-Tune protocol after an interrogation that receives no answer from th-Tune





Example of using cfg_flags

How to use Cfg_flags variable

- Bit3= 1 to display °F symbol in Big/SmallArea, and the "Temperature" is already converted by terminal
- Bit4= 1 to display PSI symbol only in BigArea, is necessary to convert only "Pressure" before displaying it on the terminal

Bit n.	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
												1	1			



NOTE: when using Modbus protocol it's necessary to write a specific coil



New management at the power on of th-Tune

- At the power ON all the keys are disabled and the Small area is showing the label "init": it will be possible only to enter in parameters menu to set the ADDRESS
- this phase is used in "th-Tune protocol" to send the acronyms of parameters; when the sending acronym phase is ended it goes out from INIT phase
- to use the th-Tune in Modbus master it is necessary to set to "1" the bit 0 of cfg_flags (see correspondent modbus coil) to make it go out of "init" phase
- during this phase anyway the th-Tune is communicating so it can be used for initialization
- •It is possible to set a "th-Tune internal parameter" (password 22) to automatically bypass this phase. The parameter is P_In and the default value of "0" must me set to "1"
- the offline of th-Tune (showing "Cn") is now after 30 seconds and it's counted from the last valid interrogation on the network; asd a consequence if the master is sendin valid modbus messages to another controller the th-Tune is ONLINE



State of display

How to manage th-Tune display state:

- Use "Power ON/OFF" button manage state of display
 - Press for 3s "Power ON/OFF" to switch on/off th-Tune display
 - **Power** variable is related to "**Power ON/OFF**" button state



- Use **Power** variable of "Functions" tab or correspondent modbus variable
 - To read display state (i.e. set by user or by scheduler***)
 - To force display state (i.e. set by application)
 - Assumes only 4 value, see table below

Value (Dec.)	Description
0	Display OFF The display is in OFF state and shows: - in BigArea "OFF" - in SmallArea the variable set (see SmallArea variables)
1	Display ON The display is active and show varaibles set in Big/SmallArea
2	Display OFF from time band In BigArea "OFF" and in SmallArea shows the variable set (see SmallArea variables) and
3	Display OFF Display is without no symbols and in OFF state





How to change "Mode" 1/3

- The "Mode" area includes several symbols: heating, cooling, etc
 - To change mode press the *Mode* button or use *Mode* variable



- Current mode (symbol/s) is indicated by variable *Mode* (Read/Write)
- The symbols can be turn on **separately** or in **pairs** (**T** etc)

Value of "mode" variable in dec	"Mode" on TH-tune			
0	Н20			
1	Dedum			
2	Auto			
3	Cool			
4	Heat			
5	Not Used			
6	Not Used			
7	Not Used			
8	Couple1			
9	Couple2			
10	Couple3			
11	Couple4			
12	Couple5			
13	Couple6			
14	Couple7			
15	Couple8			





How to change "Mode" 2/3

Example

 The symbols (and pairs) must be configured before being used with Mode_seq_mask variable

Functions		Param	neters	Icons	Scheduler	Terminal		
Icon	N	ame	De:	scription	Į V.	Variable		
	Mo	ode	Valu	ie select	ted for th	e mod M	ode	

- Mode_seq_mask enable the symbols can be turn on separately or in pairs
 - Bit0-4: enable individual symbols
 - Bit8-15: enable pairs
 - Mode_seq_mask = 0000 0000 0001 1001 bin = 25 dec





How to change "Mode" 3/3

Pairs of symbols

- The pairs of symbols must be configured before being used (max 8 pairs)
- The pairs of symbols are configured with variables *Mode_couple_12/34/56/78*
- Value to use inside *Mode_couple_12/34/56/78*
 - $H_2^0 = 0 \text{ dec} = 000 \text{ bin}$
 - Dedum = 1 dec = 001 bin
 - Auto = 2 dec = 010 bin
 - Cool = 3 dec = 011 bin
 - Heat = 4 dec = 100 bin

Example

- How to configure two pairs of symbols
 - Mode_couple_12 = 0100 0010 0010 0001 bin = 16929 dec
- Pair2=Heat+Auto Auto 15 14 13 Bit n. Pair1=Auto+Dehum Auto \Lambda 0 0 0 0 Pair 2, Symbol 2 (Pair 1, Symbol 2(الصغية) Pair 2, Symbol 1(Auto) Pair 1, Symbol 1() • Symbols/Pairs can be **enabled** with variable **Mode_seq_mask** Mode seq mask = 0100 0011 0001 1001 bin = 17117 dec ٠ Bit0-4: enable individual symbols Bit n. 15 Bit8-15: enable pairs ٠ 0 0 0 n 0 0 0 Enable 2nd pair (ë Auto

Functions		Parameters	neters Icons Alarms		Scheduler Terminal			
Icon	N	ame	1	Description	Variable			
	Mo	de_couple_1	2		thTune_MA	SK_1_Mode_couple_12		
	Mo	ode_couple_34	1		thTune_MA	SK_1_Mode_couple_34		
	Mo	de_couple_56	5		thTune_MASK_1_Mode_couple_5			
	Mo	de_couple_78	3		thTune_MA	SK_1_Mode_couple_78		



How to change "Fan"

- The "Fan" area includes **several symbols**: Fan_Speed1, Speed2, Speed3, Auto
- To change the Fan status press the Fan button or use S_Fan variable



unctions		Para	ameters	Terminal						
lcon	N	lame Description					Variable			
R	Fan		Value s	alue selected for the Fan function						

- Current **Fan status** is indicated by variable **S_Fan** (**Read/Write**)
- It is possible to **override** the fan status by using the var **Fan_control_override**

with this variable it's possible

- Overwrite one of the speed (whatever the value of fan variable is)
- Overwrite AUTO icon (off, blink)
- Overwrite FAN+speed 1 icon
- Make the fan speed request by key vary between blinking status, while is the application to confirm the value and stop the blinking





Fan_control_override: details

8

Bit	Description
0,1	Specify the type of SPEED symbols override inside "Fan area": $00 = OFF$, $01 = Speed1$ 11 = Speed3 <u>Note</u> : S_Fan variable is not affect by this selection: pressing Fan key it possible modify "S_Fan" value in "Fan area"
2	Enable override of the SPEED symbol: BIT 1-2 are used
3, 4	"Speed1" icon override: 00= no effect; 01= always OFF; 10= always ON;11= always Blink
5, 6	"AUTO" icon override: 00= no effect; 01= OFF; 10= ON;11= Blink
7	"Fan" area enable if = 1 "Fan" area disable (all symbols forced off)
8	Fan Blink request (when this bit is set to "1", the pressing of fan key makes blinking the selected speed and make it to vary between admitted values. <u>Note</u> : after pressing fan key the BIT 9 is set to 0, then application must set BIT 9 = 1 to stop blinking)
9	Fan blinking reset: works only if BIT 8 is set to "1"
10	Disable OFF selection (no fan speed); when pressing the Fan key, the "S_Fan" variable cannot assume 0 value and it's not possible to visualize no fan icon
11	Disable <i>Speed1</i> selection; when pressing the Fan key, the "S_Fan" variable cannot assume 1 value and it's not possible to visualize just <i>Speed1</i>
12	Disable <i>Speed2</i> selection; when pressing the Fan key, the "S_Fan" variable cannot assume 2 value and it's not possible to visualize just <i>Speed2</i>
13	Disable <i>Speed3</i> selection; when pressing the Fan key, the "S_Fan" variable cannot assume 3 value and it's not possible to visualize just <i>Speed3</i>
14	Disable AUTO selection; when pressing the Fan key, the "S_Fan" variable cannot assume 255 value and it's not possible to visualize Speed3 + AUTO
15	Not used

How to override "Fan" area

Example 1: overwrite

- 1. Enable override "Auto" symbol in blinking mode
- 2. Enable override "Speed 3" symbol
- 3. "Auto" symbol Blinking : bit 5-6 🗆 11
- 4. "Speed" symbols = ____ : bit 0-1 □ 11
- 5. Speed overwrite enable: bit 2=1





Example 2:

- 1. Enable blinking request: bit 8=1
- 2. User changes fan speed with FAN key: he will see only blinking icons between the admitted values (that are 1 and 3). The bit 9 will be set to 0
- 3. Application confirms speed: bit 9 = 1

Bit n.	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
		1	0	1	0	1	1	1	0	1	1	0	0	0	0	0





The "BigArea" 1/2

- The "BigArea" shows the value of one (fixed) or more variables (the Carousel)
- To define what to show use the Cfg_big_area variable

 Functions
 Parameters
 Icons
 Alarms
 Scheduler
 Terminal

 Icon
 Name
 Description
 Variable

 Cfg_big_area
 Code for big display
 Cfg_big_area

Cfg_big_area (dec. value)	Description	Variable involved
0	Displays the ' <i>Carousel of variables</i> ': that is, only the variables specified in the Bigarea_carosello_cfg (however, it is possible to use SmallArea for display another variable, see restriction to SmallArea).	Bigarea_carosello_cfg
1	Displays the room temperature measured by the pCO in °C or °F.	C_temp
2	Displays the temperature setpoint in °C or °F	Set_Temp
3	Displays the room humidity measured by the pCO in %rH.	C_hum
4	Displays the humidity set point in %rH.	Set_Humid
5	Displays the external temperature measured by the pCO in °C or °F.	External_Temp
6	Displays the pressure measured by the pCO in PSI or BAR.	C_pressure
7	Displays value of ' free variable ' n°1 in BigArea, and acronym in SmallArea (overwriting what is configured in small area)	Free_vaule1_val Free_value_1_char12/34 Free_value_1_unit
8	Displays only value of ' free variable ' n°2 in BigArea, and acronym in SmallArea (overwriting what is configured in small area)	Free_vaule2_val Free_value_2_char12/34 Free_value_2_unit
9	Displays only value of ' free variable ' n°3 in BigArea, and acronym in SmallArea (overwriting what is configured in small area)	Free_vaule3_val Free_value_3_char12/34 Free_value_3_unit
10	Displays only value of ' free variable ' n°4 in BigArea, and acronym in SmallArea (overwriting what is configured in small area)	Free_vaule4_val Free_value_4_char12/34 Free_value_4_unit

Example: Set Cfg_big_area = 7 dec, in "BigArea" is displayed only "Free variable" n°1





The "BigArea" 2/2

Example 1

- To show the room temperature read by internal sensor \Box Set Cfg_big_area=1 dec
- The "BigArea" also shows the "**Set_Temp**" value is being set by the user, when twisting the encoder (SET icon appears)

Example 2

- To show the room humidity read by internal sensor

 Set Cfg_big_area=3 dec
- The "BigArea" also shows the "**Set_Humid**" value is being set by the user, when twisting the encoder (SET icon appears)



פרק.

298







The "SmallArea" 1/2

- The "SmallArea" shows the value of a variable or the clock (similar to "BigArea")
- To define what to show use the Cfg_small_area variable

Cfg_small_area (dec. value)	Description	Variable involved
0	Displays the 'Clock' and shows the day of the week.	See clock variables
1	Displays the room temperature measured by the pCO in °C or °F.	C_temp
2	Displays the temperature set point in °C or °F	Set_Temp
3	Displays the room humidity measured by the pCO in %rH.	C_hum
4	Displays the humidity set point in %rH.	Set_Humid
5	Displays the external temperature measured by the pCO in °C or °F.	External_Temp
6	Displays only the VALUE of Free Variable 1 with unit its unit of measurement	Free_vaule_1_val Free_value_1_unit
7	Displays only ACRONYM of ' free variable ' nº 1.	Free_value_1_char12/34
8	Displays only ACRONYM of ' free variable ' n° 2.	Free_value_2_char12/34
9	Displays only ACRONYM of ' free variable ' n° 3.	Free_value_3_char12/34
10	Displays only ACRONYM of ' free variable ' nº 4.	Free_value_4_char12/34

• Some settings of **BigArea** override the ones of the **SmallArea**:

Set in BigArea	Displayed in SmallArea	
C_temp	"tE"	
Free_value*_val Free_value_*_char12/34 (acronym of varia		
*	Can be 1, 2, 3 or 4	





Example

8

• To show the room temperature read by internal sensor \Box Set **Cfg_small_area** =1 dec



The "SmallArea" 2/2



"Cfg_small_area" is not a bitfiled variable!







- "Carousel" is a simple menu for user with a short list of variables
- To select the variables included in the "Carousel" use BigArea_carosello_cfg

Bit	Description	Variable
0	Displays the room temperature measured by the pCO in °C or °F.	C_temp
1	Displays the temperature set point in °C or °F	Set_Temp
2	Displays the room humidity measured by the pCO in %rH.	C_hum
3	Displays the humidity set point in %rH.	Set_Humid
4	Displays the external temperature measured by the pCO in °C or °F.	External_Temp
5	Displays the pressure measured by the pCO in PSI or BAR.	C_pressure
6	Displays ' free value ' nº1	Free_vaule1_val, Free_value_1_unit Free_value_1_char12/34
7	Displays ' free value ' n°2	Free_vaule2_val, Free_value_2_unit Free_value_2_char12/34
8	Displays ' free value ' n°3	Free_vaule3_val, Free_value_3_unit Free_value_3_char12/34
9	Displays ' free value ' n°4	Free_vaule4_val, Free_value_4_unit Free_value_4_char12/34

•Browsing of the "Carousel"

8

- Press the "ENCODER" to display next variable of "Carousel".
- After 10s of inactivity is shown the first variable of the "Carousel"


How to configure the "Carousel" 2/2

Example

- How configure Bigarea_carosello_cfg to display
 - Temperature and humidity read by internal probes of th-Tune
 - Pressure read by pCO probe

Steps

- · Use this variables in Strategy Editor
 - Th-Tune internal probes
 - T_temp, T_hum
 - Value to display on th-Tune
 - C_temp, C_hum, C_pressure
- Configure Bigarea_carosello_cfg = 37 dec
- Configure Cfg_big_area = 0 dec

y es of th-Tune			Copy values
	· · · · · · · · · · · · · · · · · · ·	C_temp o C_pressure o c_t_hum o	Values to display on th-Tune
th-Tune internal probes	c <mark>T_temp p</mark>	In0 Sel	C_temp 0
Probe connected to pCO	T_Probe D	Sel_I	Value of temperature displayed



Note

- It's necessary to convert only **Pressure** before displaying it
- The Temperature is <u>already converted</u> by terminal
- Use Cfg_flags variable
 - Bit3: to display °C/°F symbol in Big/SmallArea
 - Bit4: to display BAR/PSI symbol only in BigArea





th-Tune internal

rohad



- The Big/SmallArea can show also two generic variables: the Free variables
- The Free variables must be configured before being used
- For each Free variables specify: value, 4-char acronym (i.e. "DIF1"), unit of meas, R/W
 properties and limits

this is an example with free variable 1

Variable	Description
Free_value_1_val	Specifies the value
Free_value_1_char12	Specifies the 1^{st} and 2^{nd} char (form right) (i.e. '1' and 'F')
Free_value_1_char34	Specifies the 3 rd and 4 th char (form right) (i.e. 'i' and 'd')
Free_value_1_unit	Specifies the unit of measurement / decimal point

Note

- Selecting **BigArea** to display the free variable vaule, in **SmallArea** will be displayed acronym of free variable
- Selecting **SmallArea** to display the free variable vaule, in **SmallArea** will be displayed **only** acronym of free variable and not variable value.



How to configure "Free variables" 2/4 Acronyms

Example

Display in **BigArea** variable "Differential" using 1st free variable

Steps

- Configure Free_value_1_char12/34 to display in SmallArea `DIF1'
 - Char: 'A' = 65dec = 0100 0001bin, etc
 - In SmallArea string `DIF1' (`diF1' displayed):

'D' = 68 dec = 01000100 bin (use CHARMAP/CALC to find char code)

'I' = 73 dec = 01001001 bin

'F' = 70 dec = 01000110 bin

- '1' = 49 dec = 00110001 bin
- Free_value_1_char12 = 17969 dec



- Free_value_1_char34 = 17481 dec





How to configure "Free variables" 3/4 **Variable configuration**

- Value displayed in BigArea
- Configure Free_value_1_unit to set
- unit of measurement

8

8

decimal point (all the exchanged variables are integer)
R, R/W property
Maximum and minimum value that can be set by the user with the encoder for R/W variables

Bit	Description
0-2	Unif Of Measurement 000: (none) 001: °C 010: °F 011: %rH 100: BAR 101: PSI 111: ppm (for custom thTune)
3	If the bit is "0" the variable can be written by the user with the encoder (set to 1 for read only variables)
4	Hide decimal point 0: the '.' is shown (in the BigArea) 1: the '.' is not shown (in the BigArea)
5,6	Multiplier for minimum & maximum 00: x1 01: x10 11: x100 11: x1000
7-10	Maximum value (only positive) from: 0 to 15 (=1111)
11-15	Minimum value (also negative) from: -15 (=10001) to 15 (=01111)





- Value displayed in BigArea
 - Configure Free_value_1_unit to set unit of measurement and decimal point
 - Set Free_value_1_unit = 17 dec
 - Set Cfg_big_area = 7 dec







- It is possible to manage the icons in the lower part of the display through some variables
- •When using th-Tune editor the variables in the **Icon** tab define the status of icons

Function	ns Parame	ters	Icons	Alarms	Scheduler	Termin	hal			
Icon	Name	Des	scription		Variable		, ()		Value	Description
<u>.</u>	Alarm	Alar	m icon		Alarms		~		0	Symbol OFF
0	Pump	Pum	np icon		Pump		~	Status of icons	1	Symbol ON
Ğ	Compres	Con	npressor	icon	Compre	ssor	×		2	Symbol blinking
33	Defrost	Defi	rost icon		Defrost		~		_	<i>-</i> ,
Show and the second sec	Fan	Fan	icon		Fans		~			
8	Boiler on	Boile	er on icor	n	Boiler_o	n	~	Example: Dlinking	85	Defrect
*	Heating	Hea	ting icon		Heating		~		4.	Derrost =
T C	Password	Pas:	sword icc	n	Passwor	rd	~	2		

When connecting the th-Tune in Modbus master it's necessary to write

correspondent holding registers to those values (0-1-2) to obtain the same result

•Note for ALARM icon

- Application can switch on symbol \mathbf{k} ,
- If an alarm is present, application doesn't switch off symbol, using "Alarms" variable.



CAREL

Management of keys pressed on the terminal 1/3

Key_buffer

- contains the code of key, or pair of keys pressed
 - (Example :"FAN" or "MODE+FAN")
- •The code is automatically set when pressing:
 - A single key
 - A couples of keys
- The *code* of key pressed and the "*pressure time*"
 - <u>are maintained</u> in key_buffer and key_buffer <u>till</u> a new key is pressed



Management of keys pressed on the terminal 2/3

Key_buffer

- It's used as bitfield variable
- It contains the code of key pressed (see table)
- In Key_timer is inserted the "pressure time" of the key pressed
- The code of key pressed and "pressure time" are maintained in key_buffer and key_buffer till a
 new key is pressed

Bit	Description
0	Key " FAN" : 1 pressed
1	Key "POWER ON/OFF": 1 pressed
2	Not used for this type of terminal
3	Not usedfor this type of terminal
4	Key "CLOCK": 1 pressed
5	Key " MODE ": 1 pressed
6	Key "ENCODER": 1 pressed
other	Reserved

18 - - - +

Example1

- •A single key pressed
 - FAN (BIT0=1 🗆 1dec)



Bit n.	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
									0	0	0	0	0	0	0	1

Example2

- •A couples of keys pressed
 - POWER_ON/OFF & CLOCK (BIT1=1 and BIT4=1 □ 18dec)



Management of keys pressed on the terminal 3/3

Key_timer 🥝

- In the first part of **Key_timer** (bit 0-7) is inserted the "*pressure time"* of a key:
 - 0: key is pressed and immediately released
 - 1..16: The key has been pressed for 1, 2 or 16 seconds since last read
 - keys sampling every ~250ms.
- Description of behavior of **Key_Timer**:
 - When the key is pressed, Key_Timer is immediately set to "**0**".
 - Meanwhile, if the button is pressed firmly for <u>at least one second</u>, Key_Timer will get an increment value starting from "1" and increasing every ~250ms, reaching a top value of "16" (corresponding to 16 seconds). When 16 is reached, it will not be incremented anymore.
- The bits 8-15... represent a counter of how many times a specific key is pressed until a new one is pressed updating key_buffer

Example

•FAN key was pressed for 3 times and now is beeing pressed since 7 seconds



Key_enable_mask

- Ø
- It is used to bitfield to *enable* or *not*, the <u>functions</u> <u>associated</u> with keys on the physical keyboard,
- Some bits are used for a "Custom Function"

Bit	Description
0	Editing "FAN" key by phisical keyboard: 1 disable, 0 enable
1	Editing "MODE" key by phisical keyboard: 1 disable, 0 enable
2	Editing "Clock Hour" (HH,MM,Day) pressing "CLOCK" key: : 1 disable, 0 enable
3	Editing "Time Bande" pressing "CLOCK" key: 1 disable, 0 enable
4	Editing "Temperature Setpoint" using "ENCODER" key: 1 disable, 0 enable
5	Editing "Humidity Setpoint" using "ENCODER" key: 1 disable, 0 enable
6	Showing "Alarms loop" pressing "MODE+CLOCK" keys: 1 disable, 0 enable
7	Showing "Res Alr" property in "Alarms loop": 1 disable, 0 enable
8	<pre>Disable "CLOCK" key short-press to enable/disable "Time Bands": Bit8= 0 "short-press" enable, Bit8= 1 "short-press" disable (see slide 12). NOTE: BIT1 of "Status_flags" variable can be used by application to display incon</pre>
9	Showing machine parameters pressing "FAN+POWER ON/OFF"
10	Enable custom function with up right key ("POWER ON/OFF")
11	Enable custom function with middle right key ("FAN")
12	Enable custom function with up left key ("CLOCK")
13	Enable custom function with middle left key ("MODE")
14	Visualize the Acronym of Free variable 3 in small area (Overrides the Cfg_Small_Area setting)
15	Visualize the Value of Free variable 3 in small area (Overrides the Cfg_Small_Area setting)

Keys functionality lock

Setting the bits in Key_enable _mask 🥥

- Only the <u>functions associated</u> with keys on the physical keyboard are locked it's <u>possible</u> to continue to read if a key is pressed and to enter other functions associated with that key
- "POWER ON/OFF" key cannot be locked
- The default value is all function keys enabled (all bit to 0)
- When trying to access a locked function the icon "KEY" appears for one second

Example

- Disable function keys
 - "FAN"
 - "MODE"

Settings in Key_enable_mask

Bit n.	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1

Pressing MODE the "KEY" icon appears showing that the function is locked





"Custom Function"

Ø

- It is possible to configure one or more buttons to enable a "Custom Function"
- The activation of the Custom Function will set the bit 4 of "*Status_flags"* variable at "1" for using this information inside the application
- it is possible to modify the visualization of the main screen overwriting the *small* area or the *big area* with the values of free variable 3 (see section..)





Management of "CLOCK" 1/2 Clock Key

"CLOCK" key

- Short press of "clock" key
 - Enable/disable "Time bands"

 - symbol is displayed
 - As a default the bit



Time bands enabled Time bands disabed

- Press "clock" key for 2s to enter in "*Clock menu*"
 - 3 selections are possible and then push "ENCODER" to confirm a selection:
 - "CLOC"
 - "TIME BAND"
 - "ESC" (ON-OFF button as a shortcut)

Selecting "CLOC"

- To configure in sequence: "Hour", "Minute" and "Day"
- Rotate "ENCODER" to change value and push to confirm
- The variables can be changed through the serial line

NOTE

It is not possible to enter in clock setting mode, if time bands are enables (Clock icon ON)





Management of "CLOCK" 2/2 Clock Visualization and variables

- Terminal can display in SmallArea
 - Hours of the th-Tune internal clock
 - Application can only read it on these variables:
 - T_clock_hrs, T_clock_min, T_clock_day
 - Pressing "CLOCK" key for 2s is possible to change them
 - Hours sent by pCO
 - Application can write/read it on these variables:
 - C_clock_hrs, C_clock_min, C_clock_day
 - Pressing for "CLOCK" key for 2s is possible to change them, and when using th-Tune protocol, BIOS change automatically system variables (CURRENT_HOUR, CURRENT_MINUTE)
- Use Bit9 of **cfg_flags** variable to set hours to display
 - Bit9=0 display internal clock (th-Tune display: T_clock_hrs, T_clock_min, T_clock_day)
 - Bit9=1 display pCO clock (th-Tune display: C_clock_hrs, C_clock_min, C_clock_day)







Time Bands Management 1/5 Time Bands Selection

Selecting "TIME BAND" after pushing CLOCK button for 2 s

- After the push of "ENCODER" terminal displays "Sel days"
 - Rotating "ENCODER" is possible to select a group of days or a single day:
 - "7 days" (mon, tue, wed, thu, fri, sat, sun)
 - "5 days" (mon, tue, wed, thu, fri)
 - "2 days" (sat, sun)
 - "Day by day"
 - "ESC" ("ON-OFF" is a shortcut for this option)



Example

- Push on "ENCODER" to confirm a selection (i.e. "7 days")
 - Then terminal asks to the user to select one of the "Active Time bands"



Time Bands Management 2/5 **Time Bands Setting**

Select one of

Push of "ENCODER"

6 "Time bands" or "ESC"

Setpoint

Start time of time

band selected

-, |- | 4845 Push of "ENCODER" 7 days 10:30 *****

- How to select single "Time band"
 - From "Sel day" select "7 days"
 - Terminal asks to select:
 - One of the 6 "Time bands"
 - "ESC" (this option can be
- Parameters of a single "**Time band**" selected
 - "Temperature Setpoint"
 - "Start time"
- How to modify parameters
 - Push "ENCODER"
 - In the sequence is possible to change
 - "Hour", "Minute", "Setpoint"
 - Push "ENCODER" to confirm each parameter
- Notes

The sequence of time bands is fixed and it is possible to view and end it only following this sequence (i.e. to go back it's necessary to keep rotating the encoder to start again from the beginning. Remember that at the application level it's possible to disable and make

disappear a time band using "*cfg flags"* variable.

Time Bands Management 3/5 Time Bands Setting

- How to "Disable a band"
 - In "*Hour*" field rotate "ENCODER" up to display "--:--"
 - Push "ENCODER" to confirm

Note

- Use these value (24, 60 and -10000) to disable a band by application, and display on terminal "--:--"
- Remember that at the application level it's possible to disable and make disappear a time band using "cfg_flags" variable.
- How to display the state "Off machine"
 - In "Setpoint" field rotate "ENCODER" up to display "OFF"
 - Push "ENCODER" to confirm

Note

- At the application level it's possible to read in the setpoint variable, this value:
 - "*Setpoint*"= -10000
- When using the internal scheduler of th-Tune also ON OFF variable is set







Time Bands Management 3/5 Overlapping control

Ø

- The data are stored in the th-Tune so when passing from a time band (hh:mm) to another one the display is proposing as starting time the hour and minute following the previous one (hh:mm+1)
- The th-Tune is checking the consistency of the time bands
 - When editing the time band: if the exhisting hour is overlapping the previous time band a compatible value is proposed
 - When trying to escape from time bands setting (ESC) with a global check: if there is any
 overlapping it is not possible to go out of the menu and the th-Tune goes directly to the
 first "inconsistent" time band proposing a compatible hour



NOTE: when changing a single day on a pre existent "multi – day" time bands, if going back in this multi day time band the inconsistent time band is disabled.





Time Bands Management 4/5 Time Bands Actions

When the time bands are enabled 🥥

At the HH:MM of the time band

- Setpoint variable is set to the stored value
- Current timeband is updated (icon is changed)
- If the time band is set to OFF the on off variable (**POWER**) is updated (=2 OFF from timeband

 When time bands are enabled key lock functionality is automatically set to disable set editing, but it's always possible to unlock the function using "key_enable_mask" variable.







Time Bands Management 5/5 Time Bands settings by BMS in Modbus only from 1.3 firmware release

- It is possible in Modbus to read and write the values for time bands used by th-Tune (registers from 256 to 339)
- The format of these information is the following "#Day Event Time #"

	Not	used	Day (fror	of we n 0 to	eek o 6)	Hour	(fro	m 0 t	o 23)		Minu	te (fi	rom () to 5	9)	
Bit n.	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0

- Another variable "#Day Event Setpoint #" is the setpoint
- To load those variables into th-Tune it's necessary to set "config_flag_5" to 1 (automaticaly set to 0 by th-Tune)

NOTE

- We suggest to disable time band editing while updating the info to keep consistency
- Writing all variables can be a long procedure so an idea is to set the terminal in "Init" mode using "config_flag_0"





Internal alarms of the th-Tune

Alarms_Mask1

- This variable collects all the alarms of the devices connected to th-Tune terminal:
 - Internal temperature probe of th-Tune
 - Board with temperature probe
 - Board with humidity probe
 - Board clock
- It's used as bitfield (see table)

Bit	Description
0	Alarm on the internal temperature probe of th-Tune
1	Alarm on second temperature probe in the t+h board (t+h models)
2	Alarm on humidity probe in the t+h board
3	Alarm on the temperature probes (it's = BIT0 OR BIT1)
4	Alarm on the board clock
other	Reserved

Example

- Alarm on
 - Board with humidity probe
 - Board clock

Bit n.	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
												1	0	1	0	0



"Alarms" tab 1/3

Inside **Alarms** tab :

- You can add some "Alarm Variable"
 - Each variable is *Integer*
- For each "Alarm variable" you can define:
 - 'Alarm status'
 - Bit15=0 alarm OFF
 - Bit15=1 alarm ON
 - 'Alarm code' is composed from 2 chars (i.e. "L19")
 - Char2 is one single alphabetic character:
 - use ASCII table("A"=65dec,"B"=66dec,...)
 - use Bit8-14 = "L"= 1001010bin
 - Char1 is a number:
 - range 0..99
 - use Bit0-7 = "19"= 00010011bin
 - Char 'A' is put by terminal
- How to configure "AL_Low_Temp" alarm variable:
 - Bit15: 0 alarm OFF, 1 alarm ON
 - Bit8-14 = "L"= 1001010bin
 - Bit0-7 = "19"= 00010011bin

Funct	ions	Parameters	Icons	Alarms	Scheduler	Terminal	
N°	Vari	iable					
001	AL_	Low_Temp					
002	AL_	High_Temp					

Order of displaying on th-Tune "*Alarms Loop*"





"Alarms" tab 2/3



- When an alarm is active "Alarm icon" is blinking
- Press "MODE+CLOCK ON/OFF" keys for 3s to enter in "Alarms Loop"
- rotate "ENCODER" to browse all active alarms
- Press "Res Alr" to try to reset all active alarms
 - This is only a request by terminal to the application
 - Application has charge
 - to reset all "*Alarm variables*" □ for each variable set the Bit15=0 ("Alarm Status" bit)
 - to manage "**Alarm_Flag**" variable
- Press "Esc" to exit from the "Alarms loop" without reset no alarms. Pressing the ON-OFF button emulates the selection of this option
- How to reset "AL_Low_Temp" alarm variable







"Alarms" tab 3/3

Alarm_Flag variable

- Use Alarm_Flag variable to develop "Alarms management"
 - Bit0: Generic alarm

15

- Bit1: Reset buzzer by user
- Bit2: Buzzer status by application
- Bit3: Buzzer mute

Set to 1 by terminal when pressing	3
"Res Alr" from "Alarm Loop"	

Set to 1 by application when some alarms are

active (now "Alarms Loop" is enable")

0

0

Bit	Name	Description
0	Generic Alarm	 How to manage from application "Generic Alarm" bit: The application sets the Bit0=1 and Bit2=1 when an alarm condition is active: In your application Bit0 is the OR of all active alarms in the system. Immediatly terminal switches on symbol and makes it blink
		 How to have access to the "Alarms Loop" Press "MODE+CLOCK" for 3s to enter in "Alarms Loop" and use "ENCODER" to display active alarms. Select "Res Alr" to reset all active alarms, this selection sets Bit1=1.
1	Reset request by user	 When selecting "Res Alr" inside "Alarms Loop" Bit1=1 (it's a request to the application). When Bit1=1 the application recieves the request from terminal to try to reset all active alarms (Bit0) Application has to reset Bit0, Bit1 and Bit2 (Buzzer sate is managed by application with Bit2).
2	Enable buzzer	If Bit3=0 then application can menage buzzer state: Bit2=0 switch off buzzer, Bit2=1 switch on buzzer
3	Buzzer mute	Buzzer is always switched off until Bit3=1
other	Reserved	Not used

15 14

Bit n.

13

12

11

10

9

8



"Parameters" tab 1/8

- The Parameter tab allows to define the "Parameters"
 - You must drag&drop variables from Variable List
- For each *parameter* you can define:
 - Type:
 - Set_Temp
 - Set_Humid
 - Set_Password
 - Set_Menu
 - (None) \square Define a Parameter
 - Variable
 - Acronym (i.e. "P12")
 - Min/Max
 - Flags

• Limitations

- Max 1 "Set_Temp" and "Set_Humid"
 - Acronym and Flags are ignored, because are dispalyed using 'Carousel'
- Max 4 variables type "Set_Password"
 - do not use '22' or '0' as password value
- Max 15 variables type "Set_Menu" (1-15)
- Max 4 chars for Acronym

N*	Туре	V	ariable	Acronym	Min	Max	Flags	
001	Set_Humid 📐	~	~		~	×	~	
002	Set_Temp	~	~		~	~	~	\$
003	Set_Menu	~	~		~	~	-	
004	Set_Password	*	~		~	×	~	

Humidity setpoint displayed Temperature setpoint displayed





"Parameters" tab 2/8

Structure of Flag variable



Limitations

- All Flag variables must be create as T-permanent with right default value
- **DEV** file must be upload inside controller
- Do not change at run-time for all Flag variables:
 - Bits value for 'Visibile', 'Category' and 'Password Level'
 - these bits are necessary to th-Tune
 - To create association between `*Category'*, '*Parameter'* and '*Password Level*'
 - To create the right file for BIOS to manage th-Tune

Bit n.	15	14	13	12	11	10	9	8	7	6	5	4	3	2	1	0
				Х					x	Х	X	x	X	X		
	rait	J_var	lable	-							7	/				

NOTES

- It's not possible to set Acronym/Flag properties for "Set_Temp" and "Set_Humid" variables
 - Flag variables are **zero**, you can manage these variables only with `*Carousel*'
 - To place these variables in a *Category* with password see appendix
- It's not possible to set "0000" as a password
- If one parameter is "read only" then it is automatically refreshed each 2 seconds during visualization
- First category is 1 :4-7 bits vary from 0001 to 1111. 0000 gives an error when compiling



duantum



"Parameters" tab 3/8

This table lists properties of Flag variable

Bit	Name	Description
0	Туре	Number type 0 = Integer number 1 = Decimal number (put decimal point on display)
1	Changing Quantum	0 = Parameter changes with step 5 (20.5 \Box 21.0) 1 = Parameter changes with step 1 (20.5 \Box 20.6)
2-3	Password Level	At each parameter is necessary to associate a Password Level. 00 = Level 0 (password with Level 0) lower access level 01 = Level 1 (password with Level 1) 10 = Level 2 (password with Level 2) 11 = Level 3 (password with Level 3) higher access level Press 'FAN+Power ON/OFF' for 3 sec, then terminal asks to insert password to start browsing inside Categories and their parameters. Within a category are not visible parameters with password level greater than password level specified. When specifing password with 'Level 3' (higher access level), it is possible to see every parameter in all Categories.
4-7	Category	Specifies which Category (max 15) the parameter belongs. It is possible to associate a password for each parameter inside a Category. The visibility of the parameters is dependent on the level of the password. 0001 = Category 1 1111 = Category 15
8-10	Unit measurement	000 = Pure number 001 = Temperature 010 = Humidity 011 = Pressure
11	R/W	Read or Write the parameter 0 = Read 1 = Read/Write
12	Visible	When this bit is set it allows to hide a parameter inside a Category 0 = Visible 1 = Not visible
other	Resrved	Not used



"Parameters" tab 4/8

Example

- To create two **Categories** everyone with a **Password** and three **Parameters**
 - In this example I suggest you a <u>rapid way</u> to create association between **Menu**, **Password** and **Parameters**
 - I use the same Key (16 and 36) to identify quickly the association on the "Parameters tab"
 - Then I use "*Strategy Editor*" to configure correctly each single *parameters*.



Do not change **Bit2-7** and **Bit12** with *Strategy Editor*.

> Set = 0

NOTE

- Some bits are necessary to create the *Category* to display when pressing "FAN+POWER ON/OFF" keys
- For each *parameter* is not possible to change *Category*, *Password level*,... (BIT 2-7/12) at "*run-time*"
- During compilation of a solution 1tool associates each parameter to a single menu in permanent mode
- To change category to a parameter is necessary to modify solution, and then upload Binary + DEV files

Functi	ons Parameters	Icons	Alarms	Scheduler	Ter	rminal							_/_	
N*	Туре	V	'ariable			Acronym	Min		Max		Flags			
001	Set_Humid	🖌 T	h_Tune_Se	et_H	~		Th_Tune_Set_H_min	~	Th_Tune_Set_H_Max	~	thTune_Term1_Hu	umid_Flag 🛛 🖌	~	
002	Set_Temp	🗸 T	h_Tune_Se	et_T	~]	Th_Tune_Set_T_Min	~	Th_Tune_Set_T_Max	~	thTune_Term1_Te	mperature_Fla	ag 🗸	$\mathbf{\mathbf{v}}$
003	Set_Menu	🗸 th	Tune_MNI	J1_MENU	~	MNU1	Password	~		~	Menu1_Flag	= 16	~	
004	Set_Menu	🗸 th	Tune_MNI	J2_MENU	~	MNI 12	Tassword	~		~	Menu2_Flag		= 36	
005	Set_Password	🗸 th	nTune_PSV	V_MNU1		= 12	Th_tune_PSW_Min	~	Th_tune_PSW_Max	~	PSW1_Flag	= 16	~	\uparrow
006	Set_Password	🗸 th	nTune_PSV	V_MNU2		= 34	Th_tune_PSW_Min	~	Th_tune_PSW_Max	~	PSW2_Flag		= 36	
007		~ v	ar_MNU1_	1	~	A001	var_MNU1_1_min	~	var_MNU1_1_Max	~	var_MNU1_Flg_1	= 16	~	T)
008		v	ar_MNU1_;	2	~	A002	var_MNU1_2_min	~	var_MNU1_2_Max	~	var_MNU1_Flg_2	= 16	~	
009		~ v.	ar_MNU1_:	3	~	A003	var_MNU1_3_min	~	var_MNU1_3_Max	~	var_MNU1_Flg_3	= 16	~	
010		V.V.	ar_MNU2_	1	~	B001	var_MNU2_1_min	~	var_MNU2_1_Max	~	var_MNU2_Flg_1		= 36	
Menu	neters of	VA V.	ar_MNU2_;	2	~	B002	var_MNU2_2_min	~	var_MNU2_2_Max	~	var_MNU2_Flg_2		= 36	
012		V V.	ar_MNU2_:	3	~	B003	var_MNU2_3_min	~	var_MNU2_3_Max	~	var_MNU2_Flg_3		= 36	



"Parameters" tab 5/8

0 0

0

0

0

11

Menu level

11

0

0

0

1

1

0

0

Password

An other way

- It's to set only the right bit for each type (*Menu, Password* and *Parameter*)
- But it's difficult to read in "Parameters tab"

Example

- For Set_Menu types only Bit4-7 are considered in reality by 1tool
 - Menu2_Flag = 36 dec
- For **Set_Password** types all Bit2-3 are considered in reality by 1tool
 - **PSW2_Flags** = 36 dec



- Do not change "run-time" Bit4-7
- Is possible to hide a parameter inside a *Menu* giving it a password level higher (Note: 4 level of password)

Bit n.

Bit n.

15 14 13 12 11 10

13 12

114

 Here the parameter is Read only so, during visualization it will be refreshed real time even without touching the encoder (that does not happen with R/W parameters). After 90 seconds the th-Tune goes back to main menu (10 s with backlight, 70 s no backlight, 10 s blinking)

How to display var_MNU2_1 parameter in a Category

- **var_MNU2_Flg1** = 36 dec
- <u>At run-time</u> **from Strategy** is possible
 - <u>use other Bits</u> to configure the parameter



"Parameters" tab 6/8

Example

- Upload software inside pCO 1.
- Press "FAN+Power ON/OFF" for 3s on th-Tune 2.
- 3. Insert password "12" and press wheel to confirm
- 4. Now you can browse categories rotating wheel
 - MNU1 \square MNU2 \square ESC \square ... 1.
 - use "ESC" to exit from editing parameters 2.
- 5. Select "MNU1" and press wheel to confirm
 - Now you can browse parameters rotating wheel 1.
 - A001 A002 A003 ESC ... (OR on OFF button) 2.
 - 3. use "ESC" to exit from "MNU1"
- 6. How to change a parameter
 - Select "A001" parameter press wheel 1.
 - 2. rotating wheel you can change "A001" parameter value
 - press wheel to confirm the new value 3.
- 7. If you select "MNU2" with password "12" you see no parameters
 - Use "ESC" to exit from editing parameters 1.
 - 2. Press "FAN+Poewr ON/OFF" for 3s on th-Tune
 - 3. Insert password "34" and press wheel to confirm
 - Now you can see all parameters in each categories 4.











How add variables when row are all completed

- Darg&Dropp variable from **Variable List** where indicate by arrow
- So you can add a new row with the variable inside

N*	Туре	Variable	Acronym	Min		Max		Flags					
001	Set_Humid	✓ Th_Tune_Set_H	🖌 A001	Th_Tune_Set_H_min	~	Th_Tune_Set_H_Max	~	thTune_Term1_Humid_Flag	~				
002	Set_Temp	✓ Th_Tune_Set_T	🖌 A002	Th_Tune_Set_T_Min	~	Th_Tune_Set_T_Max	~	thTune_Term1_Temperature_Flag	~	$\mathbf{\vee}$			
003	Set_Menu	v thTune_MNU1_MENU	MNU1		~	-	~	Menu1_Flag	~				
004	Set_Menu	thTune_MNU2_MENU	MNU2		~	•	~	Menu2_Flag	~				
005	Set_Password	V thTune_PSW_MNU1	~	Th_tune_PSW_Min	~	Th_tune_PSW_Max	~	PSW1_Flag	~				
006	Set_Password	V thTune_PSW_MNU2	~	Th_tune_PSW_Min	~	Th_tune_PSW_Max	~	PSW2_Flag	~				
007		var_MNU1_1	🖌 A001	var_MNU1_1_min	~	var_MNU1_1_Max	~	var_MNU1_Flg_1	~				
800		var_MNU1_2	🖌 A002	var_MNU1_2_min	~	var_MNU1_2_Max	~	var_MNU1_Flg_2	~				
009		var_MNU1_3	🖌 A003	var_MNU1_3_min	~	var_MNU1_3_Max	~	var_MNU1_Flg_3	~				
010		🖌 var_MNU2_1	✓ B001	var_MNU2_1_min	~	var_MNU2_1_Max	~	var_MNU2_Flg_1	~				
011		var_MNU2_2	🖌 8002	var_MNU2_2_min	Y	var_MNU2_2_Max	~	var_MNU2_Flg_2	~				
012		var_MNU2_3	✓ B003	var_MNU2_3_min	~	var_MNU2_3_Max	~	var_MNU2_Flg_3	~				
/								Variable List [MOD_TH_TUNE]					
Ro	w all co	mpleted						📝 실 Filter 🛛 🛛	3 I A	s	Array 🛛	(TPEFG	User
								Name			Descripti	ion 👘 Data type	Memo
								AOUT_MAX3			Maximum	n ph Analog	х
								AOUT_MAX4			Maximum	n ph Analog	×
								AOUT_MIN3			Minimum	ph Analog	X

AOUT_MIN4



Minimum ph... Analog

X

Parameters refresh 8/8

- Now setting the "read only" bit on parameters property this variable is automatically refreshed even without any operation made by the user: this is useful for monitoring real time changes of variables like probe reading
- The behaviour of the visualization is different: 10 seconds of backlight, then 70 seconds of visualization then blinking for 10 seconds before going out of the menu
- In parameters menu it's available the new function of ON-OFF button that is doing the same as "ESC" options in the menu







This tab collects the data of the scheduler sent by the 1.0 firmware version that did not manage internal scheduler.

The feedback we received on usage difficulty of this method led us to change the way of manage the scheduler: as a consequence this tab

Functions	Parameters	Icons	Alarms	Scheduler	Terminal				
	Hour 1	N	/in 1	Se	et 1	Hour 2	Min 2	Set 2	Chau
Day 1	24	6	60	22	0	18	30	-10000	value
Day 2	7	3	0	22	0	18	30	-10000	-
Day 3	7		30 220 18 30		30	-10000			
Day 4	7	3	0	22	0	18	30	-10000	
Day 5	7	3	0	22	0	18	30	-10000	
Day 6	ay 6 7 30		0	22	0	12	30	-10000	
Day 7	0	0		-10	0000	0	0	0	
(>	



"Terminal" tab NOT USED

- The address of the th-Tune terminal can be set in the **Terminal** tab or in the **Properties.**
- the fact that it is possible to connect just one terminal makes this feature unuseful; it's enough just to keep address 1 otherwise it's necessary to set the right address on the th-Tune

Properties	□ ‡ ×	Functions	Parameters	Icons	Alarms	Scheduler	Terminal
B ObjectLayout		Ter	minal Address	thTup	e Term1	Term Addre	224
MaskShapeColor	WhiteSmoke			unun	c	_rem_naare	
ObjectDescription							
ObjectName	Tenni						
Terminal Address	thTune Term1 Term Address						



Terminal parameters 1/2

How to access Terminal parameters

- Press 'FAN' e 'Power ON/OFF' for 3s
- Enter password `22'

NOTE

18

Do not use value '22' or '0' as password for
 Categories otherwise you have access
 terminal parameters and not to Categories



Terminal parameters 2/2

Parameters list

Code	Parameter	Unit	Min	Max	Default
Addr	Serial address	14	1	207	1
5	Baud rate:			2	
hAud	0: 4800 bps				2
DAUG	1: 9600 bps	-	0		2
	2: 19200 bps				
	Backlight behaviour:				
blda	0: The backlight will fade in but not fade out;	0.23	0	2	0
brue	1: The backlight will fade in and fade out;		<u>×</u>	2	0
	2: The backlight will not fade in and not fade out.				
bLin	Backlight intensity		0	5	4
PCal	Probe calibration	ĸ	-15	15	0
CnSt	Lcd contrast	8. <u>1</u> 8	0	15	15
bu_d	Buzzer disabled	flag	0	1	0
B 4	Password for the access to the editing of the	20112	0	999	22 Password to editing the internal parameters
PSUI	internal parameters.	-			44 Password to reset the internal parameters
P_In	Bypass Init if >0	6(27)	0	1	0
year	Year	1940	0	99	0
Mont	Month	3.40	1	12	1
mday	Month day	2.40	1	31	1
uday	Week day	1.	1	7	6
hour	Hours	19752	0	23	0
mins	Minutes		0	59	0

